



COMPLIANCE		Accessible Elevator Compliance Checklist	
		(This form may be used as a guide for checking Accessibility according with the 2019 California Building Code and shall not be considered a complete list of requirements)	
YES	NO	2019 CALIFORNIA BUILDING CODE, CHAPTER 11A AND 11B	
<input type="checkbox"/>	<input type="checkbox"/>	1.	CAR IS SELF-LEVELING WITHIN ½" [11B-407.4.4]
<input type="checkbox"/>	<input type="checkbox"/>	2.	CLEARANCE BETWEEN CAR PLATFORM AND EDGE OF LANDING = 1-1/4" MAX [11B-407.4.3]
<input type="checkbox"/>	<input type="checkbox"/>	3.	DOORS ARE AUTOMATIC, HORIZONTALLY SLIDING, [11B-407.3] AND:
<input type="checkbox"/>	<input type="checkbox"/>	A.	CLEAR WIDTH = 42" MIN. WHEN OPEN [11B-408.4.1]
<input type="checkbox"/>	<input type="checkbox"/>	B.	RE-OPEN AUTOMATICALLY WHEN SENSING OBSTRUCTION PASSING THROUGH A 5" TO 29" ABOVE FINISHED FLOOR [11B-407.3.3.1]
<input type="checkbox"/>	<input type="checkbox"/>	C.	DOORS, WHEN RE-OPENED, REMAIN OPEN FOR 20 SECONDS MIN. [11B-407.3.3.3]
<input type="checkbox"/>	<input type="checkbox"/>	4.	TIME FROM CAR ARRIVAL NOTIFICATION TO AUTOMATIC DOOR CLOSE = 5 SECONDS MIN. [11B-407.3.4]
<input type="checkbox"/>	<input type="checkbox"/>	5.	WIDTH = 80" IF CENTER-OPENING DOORS; 68" IF SIDE-SLIDE OPENING DOORS [Table 11B-407.4.1]
<input type="checkbox"/>	<input type="checkbox"/>	6.	DEPTH = 54" MIN. FROM REAR WALL TO DOORS, 51" MIN. TO RETURN PANEL [Table 11B-407.4.1]
<input type="checkbox"/>	<input type="checkbox"/>	7.	BUTTONS, HEIGHT = 48" MAX. FOR FRONT APPROACH [11B-308.2]; 48" MAX. SIDE APPROACH [11B-308.3]; 54" IF EXCEPTIONS #1 or #2 IN 11B-407.4.6.1
<input type="checkbox"/>	<input type="checkbox"/>	8.	EMERGENCY CONTROLS ARE GROUPED AT BOTTOM OF PANEL = 35" MIN. HEIGHT ABOVE FINISHED FLOOR [11B-407.4.6.4.1]
<input type="checkbox"/>	<input type="checkbox"/>	9.	EMERGENCY TELEPHONE: TELEPHONE AND EMERGENCY SIGNAL DEVICE SHALL BE PROVIDED IN THE CAR. [11B-409.4.7.1]
<input type="checkbox"/>	<input type="checkbox"/>	A.	EMERGENCY TELEPHONE HANDSET = 48" MAXIMUM ABOVE FINISHED FLOOR. [11B-308.2 & 308.3]
<input type="checkbox"/>	<input type="checkbox"/>	B.	TELEPHONE CORD LENGTH = 29" MIN. [11B-409.4.7.4]
<input type="checkbox"/>	<input type="checkbox"/>	C.	TELEPHONE IS MARKED W/RAISED SYMBOL AND BRAILLE. [11B-703.2 and 11B-703.3]
<input type="checkbox"/>	<input type="checkbox"/>	D.	COMPARTMENT DOOR HARDWARE IS COMPLIANT LEVER TYPE. [11B-409.4.7.3 -> 11B-309]
<input type="checkbox"/>	<input type="checkbox"/>	E.	EMERGENCY INTERCOMMUNICATION DOES NOT REQUIRE VOICE COMMUNICATION. [11A-1124A.4.4]
<input type="checkbox"/>	<input type="checkbox"/>	10.	CONTROL BUTTONS:
<input type="checkbox"/>	<input type="checkbox"/>	A.	DIAMETER = ¾" [11B-407.4.6.2.1]
<input type="checkbox"/>	<input type="checkbox"/>	B.	ARE RAISED 1/8" WITH SQUARE SHOULDERS [11B-407.4.6.2.1]
<input type="checkbox"/>	<input type="checkbox"/>	C.	ARE ILLUMINATED [11B-407.4.6.2.3]
<input type="checkbox"/>	<input type="checkbox"/>	D.	CHARACTERS = 5/8" MIN., RAISED TO THE LEFT OF BUTTONS [11B-403.4.7.1.1]
<input type="checkbox"/>	<input type="checkbox"/>	E.	CHARCTERS ARE WHITE ON BLACK BACKGROUND [11B-403.4.7.1.1]
<input type="checkbox"/>	<input type="checkbox"/>	F.	BRAILLE IS LOCATED TO LEFT OF EACH CHARACTER [11B-407.4.7.1.2]
<input type="checkbox"/>	<input type="checkbox"/>	G.	SPACE BETWEEN ROWS OF BUTTONS = 3/8 " MIN [11B-407.4.7.1.5]
<input type="checkbox"/>	<input type="checkbox"/>	H.	INCLUDED: "DOOR OPEN", "DOOR CLOSE", "ALARM BELL", "EMERGENCY STOP", "TELEPHONE" [11B-407.4.7.1.3 and Table 11B-407.4.7.1.3]
<input type="checkbox"/>	<input type="checkbox"/>	I.	RAISED STAR SYMBOL TO LEFT OF MAIN ENTRY FLOOR BUTTON [11B-407.2.3.1]
<input type="checkbox"/>	<input type="checkbox"/>	11.	INSIDE CAR, ILLUMINATED CAR POSITION INDICATOR IS PRESENT W/ ½" HIGH NUMERALS [11B-407.2.2.2]

<input type="checkbox"/>	<input type="checkbox"/>	12. INSIDE CAR, AUDIBLE SIGNAL IS PRESENT TO ANNOUNCE FLOOR CHANGE [11B-407.2.2.3]
<input type="checkbox"/>	<input type="checkbox"/>	13. HANDRAIL IS PROVIDED ON ONE SIDE, 1-1/2" FROM WALL, 31"-33" ABOVE FLOOR [11B-407.4.10.1]
<input type="checkbox"/>	<input type="checkbox"/>	14. FLOOR IS HARD NONSLIP, OR CARPET IS TIGHT LOOP OR LOW PILE, NO PAD [11B-302.2]
<input type="checkbox"/>	<input type="checkbox"/>	15. JAMB SYMBOLS ARE PRESENT ON BOTH SIDES, 2" MIN. RAISED, 60" ABOVE FINISHED FLOOR BRAILLE BELOW [11B-407.2.3]
<input type="checkbox"/>	<input type="checkbox"/>	16. JAMBS HAVE RAISED STAR SYMBOL LEFT OF NUMERAL ON GROUND FLOOR [11B-407.2.3.1]
<input type="checkbox"/>	<input type="checkbox"/>	17. HALLWAY:
<input type="checkbox"/>	<input type="checkbox"/>	A. CALL BUTTONS ARE CENTERED 48" ABOVE FLOOR [11B-407.2.1.1], 46" IF OBSTRUCTED BY 10"-24" IN DEPTH [11B-308.3.2]
<input type="checkbox"/>	<input type="checkbox"/>	B. BUTTONS, DIAMETER = 3/4" [11B-407.4.6.2.1]
<input type="checkbox"/>	<input type="checkbox"/>	C. BUTTONS ARE RAISED 1/8" WITH SQUARE SHOULDERS [11B-407.4.6.2.1]
<input type="checkbox"/>	<input type="checkbox"/>	D. BUTTONS ARE INTERNALLY ILLUMINATED, WHITE [11B-407.2.1.5]
<input type="checkbox"/>	<input type="checkbox"/>	E. CHARACTERS = 5/8" MIN., RAISED TO THE LEFT OF BUTTONS [11B-407.4.7.1.1]
<input type="checkbox"/>	<input type="checkbox"/>	F. VISIBLE SIGNAL FOR EACH DIRECTION = 2-1/2" MIN. DIA., CENTERED 6'-0" MIN ABOVE FINISHED FLOOR [11B-407.2.2.2]
<input type="checkbox"/>	<input type="checkbox"/>	G. AUDIBLE SIGNAL SOUNDS ONCE FOR "UP" AND TWICE FOR "DOWN" [11B-407.2.2.3]