



COMPLIANCE		<b>Accessible Signage Compliance Checklist</b> <b>(This form may be used as a guide for checking Accessibility according with the 2019 California Building Code and shall not be considered a complete list of requirements)</b>
YES	NO	2019 CALIFORNIA BUILDING CODE
<input type="checkbox"/>	<input type="checkbox"/>	1. GRADE-LEVEL EXTERIOR EXIT DOORS ARE IDENTIFIED WITH RAISED CHARACTER AND BRAILLE SIGN STATING "EXIT" [1013.4 #1]
<input type="checkbox"/>	<input type="checkbox"/>	2. EXIT DOOR TO GRADE-LEVEL EXTERIOR EXIT BY MEANS OF A STAIRWAY OR RAMP ARE IDENTIFIED WITH TACTILE SIGN AS APPROPRIATE: [1013.4 #2] "EXIT STAIR DOWN" "EXIT RAMP DOWN" "EXIT STAIR UP" "EXIT RAMP UP"
<input type="checkbox"/>	<input type="checkbox"/>	3. DOORS LEADING DIRECTLY TO A GRADE LEVEL EXIT BY MEANS OF EXIT ENCLOSURE OR EXIT PASSAGE WAY SHALL BE IDENTIFIED BY A TACTILE SIGN WITH THE WORDS "EXIT ROUTE" [1013.4 #3]
<input type="checkbox"/>	<input type="checkbox"/>	4. EACH DOOR THROUGH A HORIZONTAL EXIT IS IDENTIFIED WITH TACTILE SIGN STATING "TO EXIT" [1013.4 #5]
<input type="checkbox"/>	<input type="checkbox"/>	5. RAISED CHARACTERS AND BRAILLE FLOOR IDENTIFICATION SIGNS SHALL BE LOCATED AT THE LANDING F EACH FLOOR LEVEL ADJACENT TO DOOR ON LATCH SIDE. IN ALL ENCLOSED STAIRWAYS IN BUILDINGS 2 OR MORE STORIES IN HEIGHT, AT EXIT DISCHARGE SIGN SHALL INCLUDE A 5 POINTED STAR TO THE LEFT OF THE FLOOR LEVEL IDENTIFICATION.
<input type="checkbox"/>	<input type="checkbox"/>	6. FREESTANDING SIGNS WHOSE LOWER EDGE THAT PROTRUDE OUT WITH THE BOTTOM EDGE LOWER THEN 80 INCHES ABOVE THE FINISHED FLOOR [11B-307.3] SHALL HAVE ROUNDED OR EASED EDGES WITH A MINIMUM RADIUS OF 1/8" AT CORNERS. [11B-307.3.1]
<input type="checkbox"/>	<input type="checkbox"/>	7. SIGNAGE SPECIFICATIONS a) SIGNS THAT IDENTIFY ROOMS/SPACES OF BUILDING/SITE COMPLY WITH ALL REQUIREMENTS BELOW b) SIGNS THAT GIVE DIRECTIONS/INFORMATION COMPLY WITH REQUIREMENTS A, B, C, D, K AND L. c) SIGNS THAT INDICATE ACCESSIBILITY COMPLY WITH REQUIREMENTS A, B, K, L, M AND N
<input type="checkbox"/>	<input type="checkbox"/>	<b>REQUIREMENTS A-N</b>
<input type="checkbox"/>	<input type="checkbox"/>	A) NON-GLARE FINISH [11B-703.5.1]
<input type="checkbox"/>	<input type="checkbox"/>	B) CONTRAST BETWEEN CHARACTERS AND BACKGROUND [11B-703.5.1]
<input type="checkbox"/>	<input type="checkbox"/>	C) CHARACTERS PROPORTION WHERE UPPER CASE "O" IS 60% MINIMUM AND 110% MAXIMUM OF THE HEIGHT OF UPPER CASE "I."
<input type="checkbox"/>	<input type="checkbox"/>	D) CHARACTERS SHALL BE 5/8" MINIMUM AND 2 INCH MAXIMUM BASED ON HEIGHT OF UPPER CASE "I" (11B-703.2.5) STROKE THICKNESS SHALL BE 15% MAXIMUM TO THE HEIGHT OF UPPER CASE LETTER "I."
<input type="checkbox"/>	<input type="checkbox"/>	E) CHARACTER HEIGHT REQUIREMENTS FOR HORIZONTAL VIEWING DISTANCE (SUSPENDED/PRTOTURDING SIGNS) [TABLE 11B-703.5.5]
<input type="checkbox"/>	<input type="checkbox"/>	F) CHARACTERS ARE RAISED 1/32" MIN. [11B-703.2.1]
<input type="checkbox"/>	<input type="checkbox"/>	G) CHARACTERS ARE UPPERCASE [11B-703.2.2], SANS SERIF STYLE. [11B-703.2.3]
<input type="checkbox"/>	<input type="checkbox"/>	H) PICTORAL SYMBOLS SHALL BE 6" MIN. HEIGHT [11B-703.6.1]
<input type="checkbox"/>	<input type="checkbox"/>	I) BRAILLE IS LOCATED 3/8" MINIMUM TO 1/2" MAXIMUM FROM OTHER TACTILE CHARACTERS 3/8" FROM RAISED BORDER AND DECORATIVE ELEMENTS [11B-703.3.2] WITH EXCEPTION OF ELEVATOR CAR CONTROLS 3/16" MINIMUM BELOW RAISED CHARACTER AND SYMBOL.
<input type="checkbox"/>	<input type="checkbox"/>	J) BRAILLE DOTS ARE DOMED [11B-703.3.1], FOR DIMENSIONS SEE FIGURE 11B-705.3.1 FOR MEASURMENTS.
<input type="checkbox"/>	<input type="checkbox"/>	K) SIGN IS LOCATED ADJACENT TO LATCH OR NEAREST WALL (RIGHT SIDE PREFERRED) [11B-703.4.2]
<input type="checkbox"/>	<input type="checkbox"/>	L) FROM FINISHED FLOOR, MOUNTING HEIGHT SHALL BE 48" MINIMUM FOR THE LOWEST BASE LINE OF BRAILLE AND 60" MAXIMUM TO THE HIGHEST BASELINE OR BRAILLE CHARACTERS. [11B-703.4.1].
<input type="checkbox"/>	<input type="checkbox"/>	M) SYMBOL OF ACCESSIBILITY IS WHITE ON BLUE BACKGROUND (COLOR NO. FS15090 IN FEDERAL STANDARD 595C). ALTERNATIVE CONTRASTING COLORS MAY BE USED WHEN APPROVED BY ENFORCING AGENCY. [11B-703.7.2.1]
<input type="checkbox"/>	<input type="checkbox"/>	N) ENTRANCES/FACILITIES HAVE SIGNAGE ACCOMPANIED BY ACCESSIBLE SYMBOL INDICATING THE NEAREST ACCESSIBLE ENTRANCE/ROUTE OR FACILITY. [1143A.4]